

Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/EZ 263.03/18

Product tested	Non-Contact Safety Switches	Certificate holder	IDEM Safety Switches Ltd. 2 Ormside Close Hindley Industrial Estate Hindley Green, Wigan WN2 4HR United Kingdom
Type designation	NCR Types: LPR, SMR, SPR, WPR, MPR, CPR, CMR, WMR, MMR-H, RPR, LMR, RMR, RBR		
Codes and standards	EN 60947-5-3:2013 EN 60947-5-2:2007+ A1:2012 (in extracts)	EN ISO 13849-1:2015	
Intended application	The non-contact proximity switches in combination with a suitable monitoring unit form a PDDDB in accordance with EN 60947-5-3 and comply with the requirements of Cat. 4 / PL e of EN ISO 13849-1.		
Specific requirements	The provisions defined in the user manual and the conditions of the test report shall be maintained.		

Valid until 2023-05-23

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EZ 263.03/18 dated 2018-05-23.
This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2018-05-23

Certification Body Safety & Security for Automation & Grid

Dr. R. G. A.
Dr.-Ing. Thorsten Gantevoort