

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60085261

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
111100142

Unser Zeichen *Our Reference*
0001-jj- 28500583 001

Ausstellungsdatum
26.04.2013

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Idem Safety Switches Limited
2 Ormside Close
Hindley Industrial Estate, Hindley Gr
Wigan
WN2 4HR
United Kingdom

Fertigungsstätte *Manufacturing Plant*

Idem Safety Switches Limited
2 Ormside Close
Hindley Industrial Estate, Hindley Gre
Wigan
WN2 4HR
United Kingdom

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 2000000000

Geprüft nach *Tested acc. to*

EN 60947-1:2007
EN 60947-5-1:2004+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Interlock Safety Limit Switch

Type Designation: LSPS, HLM, HLM-SS

Max Operational Voltage: 600VAC

Rated Current: 10A

Utilisation Category: A600, AC-15 3A (240VAC)

Rated Operational current: AC-15 3A (240VAC)

Class of Protection: Class I

Protection degree: IP67

7

7

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Jon Jones