



TÜVRheinland®

ZERTIFIKAT
CERTIFICATE

No.: 968/EZ 264.02/13

Product tested	Safety Switches	Certificate holder	IDEM Safety Switches Ltd. 2 Omside Close Hindley Industrial Estate Hindley Green, Wigan WN2 4HR United Kingdom
Type designation	MMC-H, WPC, RBC, SMC, SPC, LPC, MPC, CPC, CMC, WMC, LMC, RMC, RPC, KPC	Manufacturer	see certificate holder
Codes and standards forming the basis of testing	EN 60947-5-2:1998+ A1:1999 + A2:2004 EN 60947-5-3:1999+ A1:2005 EN ISO 13849-1:2008 + AC:2009		
Intended application	Non Contact Safety Switches for interlock hinge, sliding or removal guard doors. If they are used connected to an external appropriate safety unit, they fulfil the requirements for PDF-M acc. to EN 60947-5-3 and can be used for gate monitoring in applications up to PL e, Cat. 4 acc. to EN ISO 13849-1.		
Specific requirements	The provisions defined in the user manual and the conditions of the test report shall be maintained.		
This certificate is valid until 2018-07-11.			



Type Approved

www.tuv.com
ID 0004000000

The issue of this certificate is based upon an examination, whose results are documented in report-no.: 968/EZ 264.02/13 dated 2013-07-11.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2013-07-11

Certification Body for FS-Products

Dipl.-Ing. Klaus Kemp